

Obliczenia KLIM03

terenu cisl. wezle

-	l/s	mmpm	mmpm	m	kPa	-
T1	-18.36	195.80	229.80	34.00	340.0	Zbiornik
T2	0.00	179.00	197.65	18.65	186.5	
T3	0.00	179.00	249.52	70.52	705.2	
T4	0.00	178.80	249.19	70.39	703.9	
T5	0.00	179.10	243.68	64.58	645.8	
T6	0.00	178.40	224.71	46.31	463.1	
T7	15.00	183.60	202.84	19.24	192.4	
Z1-	0.00	180.00	197.20	17.20	172.0	
Z1+	0.00	180.00	180.50	0.50	5.0	
P1-	0.00	179.30	179.76	0.46	4.6	Cisn min
P1+	0.00	179.30	249.74	70.44	704.4	
19	0.06	193.10	249.19	56.09	560.9	
17	0.00	175.50	243.68	68.18	681.8	
17A	0.02	176.90	243.68	66.78	667.8	
18	0.02	179.40	243.68	64.28	642.8	
Z3-	0.00	178.20	224.67	46.47	464.7	
Z3+	0.00	178.20	178.70	0.50	5.0	
P2-	0.00	177.70	178.68	0.98	9.8	
P2+	0.00	177.70	248.68	70.98	709.8	
8	0.00	177.90	248.68	70.78	707.8	
8R	0.00	177.90	227.90	50.00	500.0	
9	0.02	179.60	227.90	48.30	483.0	
10	0.02	177.70	227.90	50.20	502.0	
11	0.02	186.20	227.90	41.70	417.0	
7	0.00	191.10	248.47	57.37	573.7	
6	0.02	184.50	248.43	63.93	639.3	
5	0.00	198.80	248.35	49.55	495.5	
4	0.00	218.10	248.30	30.20	302.0	
3	0.00	227.70	248.29	20.59	205.9	
P3-	0.00	227.70	248.29	20.59	205.9	
P3+	0.00	227.70	318.29	90.59	905.9	Cisn max

Strona 3

STAROSTWO POWIATOWE
w Sandomierzu
27-600 Sandomierz; ul. Mickiewicza 34
tel. (15) 644-57-37 do 41, fax (15) 832-28-29